

PROPER GROUNDING OF STANDBY AND EMERGENCY POWER SYSTEMS IMPROVES RELIABILITY AND AVAILABILITY

By Ajit Bapat, P.Eng.

Power continuity is essential in many industrial and commercial installations where a trip out due to ground fault can have serious economic or operational consequences. An arcing phase-to-ground fault can pose a flash hazard to the maintenance worker close to the fault and can totally destroy the equipment. Consequential downtime adds to the economic loss. Typical grounding methods for standby generators and emergency power systems were examined for these factors and it was concluded that high resistance grounding provides the best power continuity, the best protection against arcing ground fault damage in low voltage distribution systems (up to 1000 V) and improves reliability and availability of standby and emergency power systems.

Standby and emergency systems are often configured to provide 600 V or 480 V, 3-phase 4-wire service and are thus solidly grounded. In solidly grounded systems, the ground fault currents are very high and damaging and circuit protective devices have to operate to isolate the faulty circuit and interrupt the supply. This even applies to the emergency or standby system such as a fire pump where the faulted circuit is tripped and

the system de-energized with potentially disastrous consequences if there is no power during an emergency.

BENEFITS OF PROPER SYSTEM GROUNDING

System grounding — the intentional connection of the neutral points of transformers, generators and rotating machinery to the earth ground network — provides a reference point of zero volts, which offers many advantages over an ungrounded system, including:

- Reduced magnitude of transient over-voltages
- Simplified ground fault location
- Improved system and equipment fault protection
- Reduced maintenance time and expense
- Greater safety for personnel
- Improved lightning protection
- Reduction in frequency of faults.

SOLIDLY NEUTRAL GROUNDED SYSTEMS OFFER PARTIAL PROTECTION

In a solidly grounded system, the neutral points have been intentionally connected to ground with a conductor having no intentional impedance. This reduces the problem of transient over-

voltages found on the ungrounded system and speeds the location of faults.

However, solidly grounded systems lack the current-limiting ability of resistance grounding and the extra protection this provides against equipment damage and arcing ground faults.

The well-documented destructive nature of arcing ground faults in solidly grounded systems is caused by the energy dissipated in the fault. The faulted circuits need to be tripped and with conventional time-current coordination, often it is difficult to selectively trip the circuit with minimum time delay, resulting in extensive equipment damage.

ADVANTAGES OF RESISTANCE GROUNDED NEUTRAL SYSTEMS

Resistance grounding is by far the most effective and preferred method. It solves the problem of transient over-voltages and reduces equipment damage. It accomplishes this by allowing the magnitude of the fault current to be predetermined and limited by a simple ohms law calculation:

$$I = E/R \quad \text{Where: } I = \text{Limit of Fault Current}$$

$$E = \text{Line-to-neutral Voltage of System}$$

$$R = \text{Ohmic value of neutral grounding resistor}$$

Continued on page 20

Dispose of your PCB wastes safely & economically at THE PCB incinerator site in Ontario



Our facility is conveniently located just off the 401 near Colborne Ontario

Gary Steacy Dismantling Ltd. processes:

- All transformers of any size from 0 ppm to askarel
- Light ballasts
- Cable
- Capacitors
- All PCB wastes

If a contaminated transformer is going to fall through the cracks-this is the place for it to fall.



We supply self contained bins for your oil filled or drained non PCB scrap transformers. Keep your yard clean!

Call our specialists today!

For safe and efficient disposal of your PCB and non-PCB wastes.

No more worries about residual oil!



**GARY STEACY
DISMANTLING LTD**

P.O. Box 188, Colborne ON K0K 1S0

Phone: 905-355-3046 • Fax: 905-355-5480 • email: gary@steacydismantling.com • www.steacydismantling.com

**THE
VON
CORPORATION**

205-788-2437

NEW

28KV



PRIMARY FAULT LOCATOR

**PORTABLE
POWER**

1960 JOULES

@28/14 KV

**MONOCHROME
OR
COLOR**

AUTOMATIC RADAR

TRUCK OR VAN MT AVAILABLE

VON CORP.
www.voncorp.com
Birmingham AL

Grounding Issues, Continued from page 17

In addition, limiting fault currents to predetermined maximum values permits the designer to selectively coordinate the operation of protective devices that minimize system disruption and allow quick location of the fault.

High Resistance grounding can be applied on distribution systems up to 5KV with low resistance grounding recommended at voltages between 15 and 36KV. Utility systems are usually solidly grounded, but on the secondary side of the supply transformer on the customer premises, the grounding system is independent and full advantage can be taken of the benefits provided by high resistance grounding.

High resistance grounding of the neutral limits the ground fault current to a very low level (typically under 25 amps). It is used on low-voltage systems of 600 volts or less, under 3000 amps. By limiting the ground fault current, the fault can be tolerated on the system until it can be located, and then isolated or removed at a convenient time. This permits continued production, provided a second ground fault does not occur.

High-resistance neutral grounding can be added to existing ungrounded systems without the expense of adding fault clearing relays and breakers. This provides an economical method of upgrading older, ungrounded systems.

The resistor must be sized to ensure that the ground fault current is greater than the system's total capacitance-to-ground charging current. If not, then transient over-voltages can occur.

By strategic use and location of ground fault sensing relays, troubleshooting can be greatly simplified. High-resistance neutral grounding combined with sensitive ground fault relays and isolating devices can quickly detect and shut down the faulted circuit. This provides operating personnel with the added safety that's essential in today's operating environments. Another major advantage is the elimination of dangerous and destructive flashovers to ground, which can occur on solidly grounded systems.

GROUNDING OF STANDBY GENERATORS IN 3-PHASE 4-WIRE SYSTEMS

In most large commercial buildings and industrial installations, generators are used for standby power or for emergency. So, when the distribution includes a distributed neutral, in accordance with the electrical code, it must be solidly grounded. There are three ways in which this can be integrated:

- 1) Each generator neutral is independently grounded and the neutrals are connected with grounded normal source neutral and then distributed for the load.
- 2) Generator neutrals are connected and grounded at one location. Normal supply neutral is also grounded and the common neutral is distributed for the load.
- 3) The generator common neutral is connected to the normal supply neutral and is grounded only at one location.

In (1) and (2) above the ground fault current has multiple paths through the ground and the neutral conductor to return to the source. Sensing ground fault current becomes very difficult and incorrect application may cause nuisance tripping, or the ground fault may not be sensed at all.

AUTOMATIC TRANSFER SWITCHES

Automatic Transfer Switches are used to supply the emergency load. A four-wire system necessitates the use of four pole devices with or without an overlapping neutral. The ground fault protection and coordination becomes difficult and complex. Changing the distribution to three wires overcomes this.

Connecting standby or emergency supply in a 3-phase 3-wire system only requires 3 pole transfer switches, whereas 4-wire distribution systems with the sources independently grounded require 4 pole transfer switches. In multiple source distribution schemes where single grounding location of the neutral is used, the application of ground fault protection becomes very complex and very expensive. False tripping can occur if circulating load neutral currents and the returning ground fault current are not properly sensed.

CONVERTING A SOLIDLY GROUNDED SYSTEM TO HIGH RESISTANCE GROUNDING

In most large commercial and industrial distribution systems at 600 V the single-phase 347 V load is very limited (mostly the high voltage lighting). The load is essentially 3-phase motors and transformers and therefore conversion of 3-phase 4-wire to 3-phase 3-wire is entirely practical and feasible. If the neutral is not distributed, it can be impedance grounded. Only 3 pole transfer switches are used. Small lighting transformers are used for the 347/600 V or 120/208 V distribution to service single phase loads. Figure 1 shows a typical arrangement. The generator bus is grounded through an artificial neutral and the normal supply transformer neutral is grounded through high resistance. A 3-pole Automatic transfer switch feeds the essential load. Only alarm and indication of ground fault is required and no tripping occurs in the main and standby switchboards.

Fire pumps are usually 3-wire loads and conversion to 3-wire distribution becomes an easy retrofit for existing installations. This concept is being retrofitted in a high-rise office tower in downtown Toronto. The two 1750KVA generators will be converted to high resistance grounding.

A ground alarm relay will send an alarm to the building management system on the occurrence of a ground fault. The maintenance electrician will then be able to find the faulty circuit by tracing a pulsing ground current using a hand-held multimeter while the system remains energized and working. The rest of the supply distribution will remain unaffected and is 3-phase 4-wire solidly grounded.

SUMMARY

Ungrounded delta systems have many operating disadvantages including high transient over-voltages and difficulty in locating faults.

Solidly grounded neutral systems provide greater safety for personnel, limit the system potential to ground, and speed the detection and location of the ground fault. However, the system must be shut down after the first ground fault. Applying coordinated ground fault protection is very difficult and almost impossible with multiple sources and standby generators.

Low-resistance grounded neutral systems only limit the magnitude of the ground fault current so that serious damage does not occur. The system must still be shut down after the first ground fault. This level of resistance grounding is generally used on medium and high-voltage systems.

If the power system is changed to resistance grounding, then the ground fault current can be reduced to 10 A or less which has significant impact on reducing the fire risk and equipment damage. In addition it ensures that standby power and emergency power systems continue to operate and do not suffer trip-out of a faulted feeder.

Ajit Bapat is Vice President of Technology for IPC Resistors Inc. He can be reached at abapat@ipc-resistors.com. ET




Figure 1

BABCO ELECTRIC GROUP



DYNAMIC SYSTEMS MANUFACTURER®

Since 1971

Engineers • Manufacturers • Distributors

MEDIUM VOLTAGE SWITCHGEAR

- ◆ Metal Enclosed
- ◆ Metal Clad
- ◆ Arc Resistant
- ◆ Vacuum Breaker Upgrades
- ◆ Cell Refurbishments

MEDIUM VOLTAGE MOTOR CONTROL CENTRES

LOW VOLTAGE SWITCHGEAR

LOW VOLTAGE MOTOR CONTROL CENTRES

ELECTRICAL EQUIPMENT BUILDINGS

PORTABLE AND STATIONARY SUBSTATIONS

POWER ELECTRONICS

- ◆ Low Voltage Adjustable Speed Drives
- ◆ Single Phase to Three Phase Converters
- ◆ Medium Voltage Adjustable Speed Drives
- ◆ Low Voltage Solid State Soft Starters
- ◆ Medium Voltage Solid State Soft Starters
- ◆ Inverter Systems

Uninterruptible Power Supplies

CONTROLS AND CONTROL PANELS

- ◆ Programmable Logic Controls
- ◆ Instrumentation
- ◆ Protective Relaying
- ◆ Standard Controls (Relays and Timers)

POWER GENERATION

- ◆ Standby
- ◆ Permanent
- ◆ Co-Generation

POWER FACTOR CORRECTION SYSTEMS

HARMONIC FILTERS

- ◆ Active
- ◆ Passive

ELECTRIC MOTORS

- ◆ Low Voltage (all types)
- ◆ Medium Voltage (all types)
- ◆ High Voltage (all types)

PARTS, SERVICE, TESTING AND TRAINING

**CSA Approved
ISO 9001:2000**

HEAD OFFICE AND PLANT:
12465-153 STREET P.O. BOX 3215, STN "D"
EDMONTON, AB T5L 4J1
Phone: (780) 447-1386 Fax: (780) 447-1309 Toll Free: 1-800-661-7793

www.babco-electric.com